



Certificate of Compliance

Certificate: 2065918

Master Contract: 203213

Project: 2097497

Date Issued: 2008/11/14

Issued to: Fronius International GmbH

Guenter Fronius Strasse 1

Wels-Thalheim, 4600

Austria

Attention: Mr. Josef Feichtinger

The products listed below are eligible to bear the CSA Mark shown with adjacent indicator 'US'



Issued by: Rob Hempstock, ASCT.

Authorized by: Lindsay Clark, Product Group Manager

PRODUCTS

CLASS 5311 89 - POWER SUPPLIES - Distributed Generation - Power Systems Equipment
- Certified to U.S. Standards

Utility Interactive Inverter, Models Fronius IG Plus 3.0-1 UNI, Fronius IG Plus 3.8-1 UNI, SunPower SPR-3300f, SunPower SPR-4000f, Fronius IG Plus 5.0-1 UNI, Fronius IG Plus 6.0-1 UNI, Fronius IG Plus 7.5-1 UNI, SunPower SPR-6500f, SunPower SPR-8000f, Fronius IG Plus 10.0-1 UNI, Fronius IG Plus 11.4-1 UNI, and Fronius IG Plus 12.0-3 WYE277, Fronius IG Plus 11.4-3 Delta and SunPower SPR-12000f, permanently connected.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record or the Descriptive Report or Attachment 1.

The 'US' indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL Standards, for use in the U.S.. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



CSA INTERNATIONAL

Certificate: 2065918

Master Contract: 203213

Project: 2097497

Date Issued: 2008/11/14

APPLICABLE REQUIREMENTS

*UL Std. No. 1741-First Edition - Inverter, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Including revisions through and including November 7, 2005)

*Note: Conformity to UL Std. No. 1741-First Edition (Including revisions through and including November 7, 2005) includes compliance with applicable requirements of IEEE 1547 and IEEE 1547.1