

# Certificate



Registration No.: AK 60125284 0001 Page 1/2

Report No.: 28110477 005

**License Holder:**

FRONIUS International GmbH  
Guenter Fronius-Strasse 1  
4600 Thalheim bei Wels  
Austria

**Product:**

Solar grid tied inverter

**Trademark:**

FRONIUS

**Manufacturing Plant(s):**

FRONIUS International GmbH  
Fronius Strasse 5  
4642 Sattledt  
Austria

**Model:**

Fronius Symo 10.0-3-M  
Fronius Symo 12.5-3-M  
Fronius Symo 15.0-3-M  
Fronius Symo 17.5-3-M  
Fronius Symo 20.0-3-M

**Basis:**

**CEI 0-21: 2016-07 + V1-2017**  
"Rules for the connection to the  
LV electrical Utilities"

**Factory Inspection \*\***  
To document the consistent quality of  
the product factory inspection are  
performed periodically.

**Remarks:**

\* The SUB-Manufacturing plants are under a periodic factory surveillance programme which is documented in inspection report.  
\*\* The report of the factory inspection includes the requirements of GSE applicative rules.  
In detail: visit has been performed to each factory and inspection of manufacturing process and components' check have been performed in order to guarantee a constant quality level as used for type test for compliance to CEI 0-21, for LV connection. Components' check has been based on the list of critical components indicated in the test report issued for type test for compliance to CEI EN 62109-1 (test report issued by an accredited testing Laboratory recognized under ILAC agreement).

**Certification Body**



29.11.2017

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg  
Contact: + 49 221 806 2477 email: service@de.tuv.com

**OGGETTO:** Dichiarazione di conformità alla normativa CEI 0-21:2016-07+V1:2017-07  
 “Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica”  
**SUBJECT:** Declaration of Conformity to CEI 0-21:2016-07+ V1:2017-07  
 “Reference technical rules for the connection of active and passive users to the LV electrical Utilities”



# Certificate No.: AK 60125284 0001

Page 2/2

**TIPOLOGIA DI APPARATO A CUI SI RIFERISCE LA DICHIARAZIONE:**  
**TYPE OF APPARATUS WHICH THE DECLARATION IS REFERRED TO:**

DISPOSITIVO DI INTERFACCIA Interface Device	PROTEZIONE DI INTERFACCIA Interface Protection Device	DISPOSITIVO DI CONVERSIONE STATICA Static Conversion Device	DISPOSITIVO DI GENERAZIONE ROTANTE Rotating Device
<input checked="" type="checkbox"/> (***)	<input checked="" type="checkbox"/> (***)	<input checked="" type="checkbox"/>	<input type="checkbox"/>

(\*\*\*) : internal device for models with Nominal output power less than 11.08KW.

**Costruttore** / **Manufacturer**: FRONIUS International GmbH  
 Guenter Fronius-Strasse1 4600 Thalheim bei Wels - Austria

Modello/Tipo Model/Type	Max. Potenza Apparente Maximum Apparent Power [VA]
Fronius Symo 10.0-3-M	10000
Fronius Symo 12.5-3-M	12500
Fronius Symo 15.0-3-M	15000
Fronius Symo 17.5-3-M	17500
Fronius Symo 20.0-3-M	20000

**Firmware release**: RECERBO V0.3.13.4; SYMOPS12 V0.25.9.0; SYMOFIL12 V0.9.14.1

**Numero di Fasi** / **Number of Phases**: Trifase / Three-phase

**Note** / **Remarks**: Il dispositivo è in grado di limitare la I<sub>dc</sub> allo 0.5% della corrente nominale.  
 The device is capable to limit the I<sub>dc</sub> to 0.5 % of the nominal current

**Laboratorio di Prova** / **Test Laboratory**: TÜV Rheinland Italia S.r.l. (Accreditamento ACCREDIA N. 1356)

Esaminati i Fascicoli Prove N./ Having assessed the Test Files N.:  
 28110477 001/ 005 emesso da TÜV Rheinland Italia S.r.l. / 28110477 001/ 005 issued by TÜV Rheinland Italia S.r.l


si dichiara che i prodotti indicati soddisfano i requisiti della CEI 0-21:2016-07+V1:2017-07 “Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica”  
 we declare that the products indicated meet the requirements laid down by CEI 0-21:2016-07+V1 2017-07  
 “Reference technical rules for the connection of active and passive users to the LV electrical Utilities”.

**Validità della Dichiarazione** / **Validity of the Declaration**: Questa Dichiarazione è valida per i prodotti indicati, così come descritti nei Fascicoli citati. Nuovi requisiti o emendamenti a requisiti esistenti, così come modifiche ai prodotti, possono implicare nuove verifiche e certificazioni.  
 This Declaration is valid only for the products indicated herein, as described in the Files mentioned. New requirements or amendment to existing ones, or modifications to the product, may imply re-verification and re-certification.

Date: 29.11.2017

Certification Body

**Signature**:   
 M. Piva



**TÜV Rheinland LGA Products GmbH – Tillystraße 2 – 90431 Nürnberg**