



SHIFTING THE LIMITS

**Fronius International GmbH**

**Günter Fronius Strasse 1**

**4600 Thalheim bei Wels**

## DECLARATION


Fronius International hereby confirms that the DC injection limit of 0.5% of nominal AC current is not exceeded by the following PV inverters according to UNE 206007-1 IN.

Fronius Symo Hybrid 3.0-3-S

Fronius Symo Hybrid 4.0-3-S

Fronius Symo Hybrid 5.0-3-S

Thalheim, 10.02.2017

  
FRONIUS INTERNATIONAL GMBH  
Günter Fronius Feichtinger Josef  
Tel: +43 (0) 74 42 24 00 1 25