

Manufacturer Declaration

Herstellererklärung

Tigo TS4-A-F / TS4-A-2F / TS4-A-O / TS4-X-O

Fronius International GmbH

Hereby confirms the compatibility of following Fronius inverter families with Tigo TS4-A-F, TS4-A-2F, TS4-A-O and TS4-X-O:

- **Fronius Primo GEN24 (Plus) (SC)**
(from software version 1.38)
- **Fronius Primo GEN24 208-240 (Plus)**
- **Fronius Symo GEN24 (Plus) (SC)**
- **Fronius Verto (Plus)**
- **Fronius Tauro**
- **Fronius Tauro ECO**

Settings

For optimal compatibility the following settings need to be made in the inverter interface:

- for Tigo TS4-A-F and TS4-A-2F:
DPM mode: on (with MLSD)
- for Tigo TS4-A-O and TS4-X-O:
DPM mode: off
Exception, if only partially optimized (not all panels) DPM can stay turned on.

Warranty

The use of Tigo TS4-A-F, TS4-A-2F, TS4-A-O and TS4-X-O in accordance with this declaration of compatibility does not restrict the warranty claims of the Fronius system.

Fronius does not accept any liability for the correct functioning of the optimization, monitoring or rapid shutdown, the proper functionality of which is exclusively the responsibility of the mentioned Tigo products.

bestätigt hiermit die Kompatibilität der folgenden Fronius-Wechselrichterfamilien mit Tigo TS4-A-F, TS4-A-2F, TS4-A-O und TS4-X-O:

- **Fronius Primo GEN24 (Plus) (SC)**
(ab Softwareversion 1.38)
- **Fronius Primo GEN24 208-240 (Plus)**
- **Fronius Symo GEN24 (Plus) (SC)**
- **Fronius Verto (Plus)**
- **Fronius Tauro**
- **Fronius Tauro ECO**

Einstellungen

Für optimale Kompatibilität müssen folgende Einstellungen in der Wechselrichter-Benutzeroberfläche vorgenommen werden:

- für Tigo TS4-A-F und TS4-A-2F:
DPM-Modus: Ein (mit MLSD)
- für Tigo TS4-A-O und TS4-X-O:
DPM-Modus: Aus
Ausnahme: Bei nur teilweiser Optimierung (nicht alle Module) kann DPM aktiviert bleiben.

Garantie

Die Verwendung von Tigo TS4-A-F, TS4-A-2F, TS4-A-O und TS4-X-O entsprechend dieser Kompatibilitätserklärung schränkt die Gewährleistungsansprüche des Fronius-Systems nicht ein.

Fronius übernimmt keine Haftung für das korrekte Funktionieren der Optimierung, Monitoring oder Rapid Shutdown Funktionalitäten, für deren ordnungsgemäße Funktion ausschließlich die angeführten Tigo-Produkte verantwortlich sind.



Fronius International GmbH

Solar & Energy

Froniusplatz 1

4600 Wels


Fronius International GmbH
Froniusplatz 1, A-4600 Wels
Tel: +43 (0)7252/241-0, Fax: 241-3013

Philipp Rechberger

Group Lead System Integration